

Electrical Safety for Non-Qualified Employees - Answer Key

29 CFR 1910.332 / 1910 Subpart S

1. A non-qualified employee should:
A - Perform only electrical-related work they are trained/authorized to do
2. A cord with exposed conductor should be:
A - Removed from service
3. Electrical panel working space should be:
A - Kept clear
4. A missing grounding pin is:
A - A defect that requires the equipment/cord to be removed from use
5. Wet conditions generally:
A - Increase electrical shock risk
6. If a person is in contact with energized equipment, a rescuer should:
A - Avoid touching them until the electrical source is safely controlled
7. Qualified electrical work requires:
A - Specific knowledge, training and employer authorization
8. Overhead electrical hazards require:
A - Maintaining safe clearance and following applicable procedures
9. Defective electrical equipment should be:
A - Tagged/removed from service per employer procedure
10. This awareness course makes someone a qualified electrical person.
A - False

Awareness for non-qualified employees. Only qualified persons may perform work that requires the knowledge/skills and permissions assigned to qualified electrical workers.